

The Tennessee Division of Air Pollution Control (TDAPC) has received requests for construction and/or modification of air contaminant sources as noted below. The proposed construction and/or modification is subject to part 1200-03-09-.01(1)(h) of the Tennessee Air Pollution Control Regulations, which requires a public notification and 30-day public comment period. Interested parties may express their comments and concerns in writing to air.pollution.control@TN.gov or Ms. Michelle W. Owenby, Director, Division of Air Pollution Control, William R. Snodgrass Tennessee Tower, 312 Rosa L. Parks Avenue, 15th Floor, Nashville, Tennessee 37243 within 30 days of the date of this notice. Questions concerning a source may be addressed to the assigned Division personnel at the same address or by calling 615-532-0554.

Construction permits issued by TDAPC do not grant any authority operate, construct, or maintain any installation in violation of any law, statute, code, ordinance, rule, or regulation of the State of Tennessee or any of its political subdivisions.

Individuals with disabilities who wish to participate should contact the Tennessee Department of Environment and Conservation to discuss any auxiliary aids or services needed to facilitate such participation. Such contact may be in person, by writing, telephone, or other means, and should be made no less than ten days prior to the end of the public comment period to allow time to provide such aid or services. Contact the Tennessee Department of Environment and Conservation ADA Coordinator, 22nd Floor, William R. Snodgrass Tennessee Tower, 312 Rosa L. Parks Avenue, Nashville, TN 37243, (615) 532-0207. Hearing impaired callers may use the Tennessee Relay Service (1-800-848- 0298).

The applicant is Blalock Lumber Company, L.P. dba Concrete Plant 1 with a mailing address of PO Box 4750, Sevierville, TN, 37864. The applicant seeks to obtain an air contaminant permit (Division identification number: 78-0061 and 81646 for the construction at the following address: 1225 Parkway, Sevierville. The permit request is for the modification of the following: The source emissions calculations are updated with more recent AP-42 emission factors, there is no actual increase in emissions. There would not be physical construction. Regulated air contaminants are emitted by this source. Information regarding this source can be found in the Division of Air Pollution Control Dataviewer link which can be found at the bottom of the Division of Air Pollution Control webpage.

Anna Pettit is the assigned Division person.